

Nadcap Compliance statement for Eurotherm products

Eurotherm manufactures instrumentation that, when subject to field calibration, certification and labelling requirements of AMS2750G meets the accuracy requirements of AMS2750G table 3 for "Control, Monitoring and Recording Instruments" and "Field Test Instruments".

When subject to the necessary field calibration, "Control, Monitoring and Recording Instruments" manufactured by Eurotherm are suitable for use in Nadcap applications in all furnace classes A - E as defined in AMS2750G clause 3.3.1. Process instrumentation should always be installed and used in accordance with the instructions, that accompany the product.

Eurotherm products¹ covered for "Control, Monitoring or Recording Instruments" are as follows:

- EPC3000 Programmable Controllers range EPC3016, EPC3008, EPC3004
- **EPC2000 Programmable Controller**
- 2000 series of controllers 2604 and 2704
- 3000 series of controllers 3200 series and 3500 series
- 6000 series of graphical recorders 6100A and 6180A
- nanodac™ recorder / controller
- versadac™ scalable recorder
- PAC Solutions: T2550 and T2750
- PLC Solutions: E+PLC400

Eurotherm products covered for "Field Test Instruments" are as follows:

6000 series of graphical recorders 6100A and 6180A when used with external CJC

Eurotherm products covered for Data Acquisition that are compliant to 3.2.7 Electronic records are as follows:

- 6000 series of graphical recorders 6100A and 6180A, 6100XIO and 6180XIO
- nanodac recorder / controller
- Eycon HMI
- PAC Solutions: T2550 and T2750 versadac scalable recorder
- PLC Solutions: E+PLC400

¹Featured products as listed. If you have a query about a product not on this list, please contact your local Eurotherm office.

For Eurotherm and Watlow - 22 November 2023

Peter Sherwin Global Account Manager

Kevin Robinson Sr Business Development Manager

Eurotherm Ltd. Faraday Close, Worthing West Sussex BN13 3PL United Kingdom.

Tel: +44 (0)1903 263333

Registered in England No 853008







